

Park District of Highland Park

2021 Rosewood Park Drainage/Grading Improvements Project

ADDENDUM #1

Wednesday, February 17, 2021

ISSUED BY:

Michael Evans
Park District of Highland Park
636 Ridge Road
Highland Park, IL 60035

NOTICE TO ALL BIDDERS:

The attention of all Bidders is called to this Addendum. This Addendum to the 2021 Rosewood Park Drainage/Grading Improvements Project documents is issued to modify, explain or correct the original documents. It is hereby included in and made part of the Bid Contract Documents and Project Manual, whether or not attached to.

All requirements of the original Project Specifications, Scope of Work and Drawings shall remain in force except as amended by this document.

There have been a few questions asked by potential bidders for clarification as follows:

Item # 1 – Crane Use:

- “Could access to the ravine (Energy Dissipating Structure #1), be made from the adjacent parking lot using crane mats to span the creek line?”
Yes. The Park District will need to approve and will require specifications on the type, thickness, ect of the proposed mat to be used prior to the start of construction. No access will be allowed over the existing boardwalk and surrounding area.
- “Could a crane be staged in the parking lot adjacent to the ravine (Energy Dissipating Structure #1), to pick and set material and equipment over the creek line to where the work will be performed?”
Yes. The Park District will need, prior to the start of construction, a schedule of the arrival and departure of the crane and duration on site. The Park District and contractor will determined the area in which the crane will be located in the parking lot.

Item # 2 – PVC Piping:

- “With regards to the bore shot going from Catch Basin #2 to Energy Dissipation Structure #1, would the Park District of Highland Park be open to this being installed using 8” PVC Certa-Lok pipe in lieu of fused HDPE?”
Yes. Certa-Lok with SDR- 18, C900 is an approved equal.

- “For the Directional Drilling are we allowed to use a Certa-Flo or Certa-Lok PVC Pipe instead of HDPE?”

Yes. Certa-Lok with SDR- 18, C900 is an approved equal.

- “And for the HDPE Pipe I couldn’t find any specs for the pipe I would need to know if it is DIPS or IPS and what the DR Rating is (DR 11 is most typical.)”

Yes. Certa-Lok with SDR- 18, C900 is an approved equal.